



Government of the Punjab  
Board of Revenue  
Project Management Unit  
No.  
Ph: 042-37581648 Fax: 042-37522498  
Dated Lahore,

To,

Subject: **REQUEST FOR QUOTATION (RFQ) FOR PROVISION OF UPS UNDER LAND RECORDS MANGEMENT & INFORMATION SYSTEMS PROJECT (PHASE-I), PUNJAB.**

Land Records Management & Information Systems (Phase I) is a World Bank Assisted Project of the Board of Revenue, Government of the Punjab. The Project Management Unit, Board of Revenue intends to procure UPS. You are requested to provide a quotation for UPS with following specifications: -

### **1. Technical Specifications**

<b>Item-1</b>	<b>UPS 8KVA</b>	<b>Quantity-1</b>
<b>Sr. No.</b>	<b>Item</b>	<b>Description</b>
1.	Capacity	8KVA (6400 Watts or higher)
2.	Form Factor	Rack Mounted
3.	Online	Online Double Conversion
4.	Surge Protection	Required
5.	Waveform Type	True Sine Wave
6.	Back Time	<b>20 Minutes on 5760 Watts of load or higher</b>
7.	Typical recharge time	Maximum 4 hours
8.	Status Display (Control Panel)	LED / LCD status display with load and battery bar-graphs and On Line : On Battery : Replace Battery : Overload and Bypass Indicators
9.	Audible Alarm	Required: Alarm when on battery : distinctive low battery alarm : overload continuous tone alarm
10.	Interface	USB or RS-232
11.	Battery	Maintenance Free Dry Batteries
12.	SNMP/ Monitoring	SNMP Enabled (Optional) Monitoring Software Required
13.	Output Connections	1 x Hard Wire 3-wire (H N + G) 6 x IEC 320 C13 , C19 or more
14.	Power Cables	8 Power Cables (Male Female Extensions)
15.	Accessories	Data USB /RS-232, Rack rails/ mountings for UPS and Battery Banks



16.	Battery Bank	If added, batteries and the battery bank must be of the same brand and clearly mentioned in response.
-----	--------------	---

Item-2	UPS 500VA	Quantity-25
Sr. No.	Item	Description
1.	Capacity	500VA (300 Watts or Higher)
2.	Form Factor	Small / Mini Tower
3.	Topology	Standby
4.	Surge Protection	Required
5.	Back Time	<b>5 Minutes on full Load(300 Watts)</b>
6.	Status Display	LED /LCD Status Display
7.	Alarm	Required: Should indicate Battery in use, Battery discharged, UPS Fault/ Overload
8.	Battery	Maintenance Free Dry Battery
9.	Power Cables	4 x Power Cables (Male / Female) 1 x Power Cable (3 Pin)

## 2. Delivery Schedule

- a. The supplier is responsible for delivery of equipment to the final place of destination at it's own cost.
- b. The delivery schedule is as under.

Service Center	UPS 8KVA	UPS 500VA	Delivery Date
Lahore	1	25	5 Days from Issue of Purchase Order

## 3. Related Services

- a. The supplier will provide the following service at the place of delivery before inspection.
  - i. Wiring for Input from ATS / DB (7/0.044)
  - ii. Wiring for Output from UPS (7/0.044)
  - iii. Installation of Battery Bank.
  - iv. The Vendor will provide Preventive Maintenance after every 6 months for three years from the date of delivery of equipment at the site offices at their own expense.

**Note:** For evaluation cost of 25 feet of wiring will be considered.



#### **4. Performance Security**

- a. The Vendor / Supplier is required to submit 2% performance security in the form of DD, PO, Bank Guarantee. The Performance security shall be released when the tenure for after sales services / warranties expired.

#### **5. Qualification Requirements**

- a. The supplier must provide a manufacturer / distributor authorization letter.
- b. The supplier must provide NTN, GST and company registration certificate.
- c. The equipment quoted must be branded and of International repute. The quotation(s) if any, for unbranded equipment shall be treated as non-responsive.
- d. The Purchaser shall award the purchase order to the Supplier that offers the lowest evaluated price that meets the technical specifications and qualification requirements.
- e. In accordance with Para 1.8 of the Guidelines: Procurement under IBRD Loans and IDA Credits, dated May 2004, the Bank permits firms and individuals from all countries to offer goods, works and services for Bank-financed projects. With reference to paragraph 1.8(a)(i) of Procurement Guidelines under IBRD Loans and IDA Credits following countries are excluded from this bidding.
  - i) India
  - ii) Israel

#### **6. Terms & Conditions.**

- a. The period of validity of the Warranty shall be, “3 Years” (3/3/3) “Comprehensive” for UPS “On Site” from the date of acceptance of equipment. However for UPS Battery, 1 Year replacement warranty is required.
- b. The period for repair or replacement shall be: 3 Working days. Subject to approval from the Purchaser, the time mentioned may be extended accordingly.
- c. If the Supplier fails to deliver any or all of the Goods by the Date(s) of delivery or perform the Related Services within the



period specified in the RFQ, the Purchaser may deduct from the PO Price, as liquidated damages, a sum equivalent to 0.5% per week up to a maximum deduction of 10%. Once the maximum is reached, the Purchaser may terminate the purchase order.

- d.** The Supplier shall not be liable for forfeiture of its liquidated damages, or termination for default if and to the extent that its delay in performance or other failure to perform its obligations as a result of an event of Force Majeure. For purposes of this Clause, “Force Majeure” means an event or situation beyond the control of the Supplier that is not foreseeable, is unavoidable, and its origin is not due to negligence or lack of care on the part of the Supplier. Such events may include, but not be limited to, acts of the Purchaser in its sovereign capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions, and freight embargoes.
- e.** Technical brochures must be provided with the quotation.
- f.** Based on the quotation/information provided by you, the evaluation of quotation shall follow sound public sector practices of the purchaser. The terms & conditions of the accepted offer shall be incorporated in Purchase order.
- g.** The Project Management Unit for Land Records Management & Information Systems, Board of Revenue, Punjab will not be responsible for any costs or expenses incurred by firms in connection with the preparation or delivery of quotations.
- h.** The PMU-BOR reserves the right to accept or reject one or all the quotations either fully or partially without assigning any reason.
- i.** All prices quoted must include any Taxes applicable, such as GST, Income Tax, etc. If not specifically mentioned in the Quotation, it will be presumed that the prices include all the taxes. Any variation in government taxes or foreign currency exchange rate will be on suppliers account.
- j.** The firms should clearly mention terms and conditions of service agreements for the supplied equipment after the expiry of initial warranty period. In case of International Warranties, the local authorized dealers should mention their service and warranty setup, details of qualified engineers.



- k.** Complete payment will be made only after the acceptance of equipment.

## **7. Inspections & Tests**

In addition to the inspections and tests carried out by the Supplier the nominated team of the Purchaser will perform the following inspections /tests within 10 days of delivery of equipment and will issue an NOC on acceptance of equipment.

- a.** Check the conformance of supplied equipment with the specification of this RFQ Document.
  - b.** That the equipment is brand new and in working condition.
  - c.** Any other tests that may include physical, electrical and/or software verification but not limited to it.
- 8.** If, so desired please offer your sealed quotation including technical specifications, Price including all taxes at the destination, Delivery Schedule and validity of quotation. The quotation should be sent to this office latest by Saturday, 20<sup>th</sup> Aug, 2011.

**Provincial Network System  
Administrator**